

E/One Station Sizing

Quick Reference Guide to Selecting a Grinder Pump Station

Sizing and selecting an appropriate grinder pump station is important for ensuring long life of the pump. The following are basic guidelines for station sizing. Contact E/One if you need further assistance.

Residential Applications

Single-Family Homes

- Refer to local regulations for daily flow. E/One assumes 200-300 gallons per day (gpd) or 750-1300 liters per day (lpd).
- DH07I and WH10I are the most common stations
- DH15I or WH23I is recommended for homes with 6+ bedrooms or large whirlpool bathtubs

Multi-Family Homes

- Assume 200-300 gpd (750-1300 lpd) per residence per day
- Refer to the E/One Station Capacity chart or the Product Catalog section at eone.com/sewers to find a station rated for sufficient daily flows



Commercial Applications

1. Estimate the Total Daily Flow
 - Use Table H 201.1 (4) from 2021 UPC Appendix H. Other UPC versions are available at iapmo.org. Note: Previous versions of the UPC referred to this table as Appendix K.
 - Base flows on occupancy, not fixture count
 - No “peaking” needs to be applied
2. Select an E/One Station
 - Station GPD/LPD flow rating should be greater than the flows in Step 1
 - Refer to the Product Catalog at eone.com/sewers or the E/One Station Capacity chart
3. Calculate peak flow and confirm number of pumps
 - GPD or LPD divided by peak flow time. E/One uses 4 hours for peak flow time, but may vary.
 - Confirm the number of pumps is suitable for peak flow:

$$\text{GPD or LPD} / 4 \text{ hours} / 60 \text{ minutes} = \text{Peaked Gallons or Liters per Minute}$$

1-15 gpm (6-47 lpm) = Simplex station (1 pump) or Duplex station (2 pumps)

16-60 gpm (48-240 lpm) = Quadplex station (4 pumps)

Visit the E/One Design Center at
eone.com/sewers for more information

UPC TABLE H 201.1(4)

<u>Type of Occupancy</u>	<u>Gallons (liters) Per Day</u>
1. Airports.....	15 (56.8) per employee 5 (18.9) per passenger
2. Auto washers.....	Check with equipment manufacturer
3. Bowling alleys (snack bar only).....	75 (283.9) per lane
4. Camps	
Campground with central comfort station.....	35 (132.5) per person
Campground with flush toilets, no showers.....	25 (94.6) per person
Day camps (no meals served).....	15 (56.8) per person
Summer and seasonal.....	50 (189.3) per person
5. Churches (Sanctuary).....	5 (18.9) per seat
with kitchen waste.....	7 (26.5) per seat
6. Dance halls.....	5 (18.9) per person
7. Factories	
No showers.....	25 (94.6) per employee
With showers.....	35 (132.5) per employee
Cafeteria, add.....	5 (18.9) per employee
8. Hospitals.....	250 (946.4) per bed
Kitchen waste only.....	25 (94.6) per bed
Laundry waste only.....	40 (151.4) per bed
9. Hotels (no kitchen waste).....	60 (227.1) per bed (2 person)
10. Institutions (Resident).....	75 (283.9) per person
Nursing home.....	125 (473.2) per person
Rest home.....	125 (473.2) per person
11. Laundries, self-service	
(minimum 10 hours per day).....	50 (189.3) per wash cycle
Commercial.....	Per manufacturer's specifications
12. Motel.....	50 (189.3) per bed space
with kitchen.....	60 (227.1) per bed space
13. Offices.....	20 (75.7) per employee
14. Parks, mobile homes	
picnic parks (toilets only).....	250 (946.4) per space
recreational vehicles	
without water hook-up.....	75 (283.9) per space
with water and sewer hook-up.....	100 (378.5) per space
15. Restaurants – cafeterias.....	20 (75.7) per employee
toilet.....	7 (26.5) per customer
kitchen waste.....	6 (22.7) per meal
add for garbage disposal.....	1 (3.8) per meal
add for cocktail lounge.....	2 (7.6) per customer
kitchen waste – Disposable service.....	2 (7.6) per meal
16. Schools – Staff and office.....	20 (75.7) per person
Elementary students.....	15 (56.8) per person
Intermediate and high.....	20 (75.7) per student
with gym and showers, add.....	5 (18.9) per student
with cafeteria, add.....	3 (11.4) per student
Boarding, total waste.....	(378.5) per person
17. Service station, toilets.....	1000 (3785) for 1st bay 500 (1892.7) for each additional bay
18. Stores.....	20 (75.7) per employee
public restrooms, add.....	1 per 10 sq. ft. (4.1/m2) of floor space
19. Swimming pools, public.....	10 (37.9) per person
20. Theaters, auditoriums.....	5 (18.9) per seat
drive-in.....	10 (37.9) per space

E/ONE STATION CAPACITY

Complete product information, drawings and specifications are available in the Product Catalog at eone.com/sewers.

D-Series Model	W-Series Model	Basin ID (in)	Rated GPD (LPD)	Ideal Number of Houses	Houses Up To	Max Houses with Consent*
DH071	WH101	24	700 (2650)	1	1	2
	WH231	24-42	850 (3200)	1	1	2
DH151		36	1500 (5678)	1	4	6
DH152		36	3000 (11,356)	4	8	12
	WH472/WH482	42	3500 (13,249)	5	9	14
DH272		48	5000 (18,927)	6	13	19
DH502		60-72	6000 (22,712)	9	15	23
	WH483	42	5000 (18,927)	8	13	19
	WH484	42	7000 (26,498)	10	18	26
The following models refer to W-Series Fiberglass Stations						
	Duplex	48	5000 (18,927)	6	13	19
	Triplex	48	6500 (24,605)	10	17	25
	Quad	48	8500 (32,176)	12	22	32
	Duplex	60	6000 (22,712)	9	15	23
	Triplex	60	7500 (28,391)	12	19	29
	Quad	60	9500 (35,961)	14	24	36
	Triplex	72	8500 (32,176)	14	22	32
	Quad	72	10,500 (39,747)	16	27	40

*Where codes allow. Please consult with E/One.

Disclaimer: This information is provided for reference only. The station size is ultimately the responsibility of the engineer of record. E/One's recommendations are based on demonstrated performance in a variety of applications and regions. Selecting the best station is important. Oversizing a station may lead to issues related to odor and corrosion. Undersizing a station may lead to nuisance alarms and possible overflows.